




Office of the Fire Chief
BROOKLINE FIRE DEPARTMENT
4 Bond Street, Brookline NH



May 4, 2023


Case SD#2023-I:D-007

Dear Members of the board

The fire department has reviewed the proposed plan for the sub-division of lot D-7. The following items need to be addressed:

1. The size of the culvert pipe for the drafting basin on the plan calls for a 12" when in fact it needs to be an **18"** pipe going into the basin. And the pipe must be HDPE.
2. The basin must be installed and constructed to the specifications of appendix F of the sub-division regulations.
3. All aspects of section 4.5 of the sub-division regulations must be followed.

Should the board have any questions please don't hesitate to contact me at the firehouse.


Charles E. Corey, Sr.
Fire Chief