




Office of the Fire Chief
BROOKLINE FIRE DEPARTMENT
4 Bond Street, Brookline NH



July 21, 2022

RE: SP# 2022-B. H:42 AMENDED

Dear members of the Planning Board:

The fire department has reviewed the updated plans submitted for the proposed club house at the housing for older persons development located at 23-25 main street.

The plans are for a 336 sq. foot meeting room at the club house. This is under the requirement for a commercial sprinkler system.

Should you have any questions or concerns please don't hesitate to contact me.

Charles E. Corey, Sr
Fire Chief