




Office of the Fire Chief
BROOKLINE FIRE DEPARTMENT
4 Bond Street, Brookline NH



October 25, 2022

Re: Older Person Housing at 25 Main St.

To Whom it May Concern:

This letter is to inform the Brookline Planning Board of our findings regarding the proposed water source on Monius Way.

The water sources that the developer has proposed is a unique configuration that we have not experienced in town to date. Because of this, we will need to use one of our fire engines to ensure that this will meet the flow rate requirement of 1000 gallons per minute for a minimum of 30 consecutive minutes that we have for our water sources.

We recommend that no Certificates of Occupancies are distributed until after the cistern has passed the pump test.

If you have any questions, please contact me at the fire department.

Sincerely,

Chief Charles E. Corey, Sr.